



CONSULTING
GROUP

Vibration Monitoring Report Summary

Slauson Middle School
Renovation and Addition

Project Number: 253121

Date: 03/20/26 to 4/02/26

Client: Ann Arbor Public Schools

Client Contact: Erik Bodker (Gilbane)

Project Address: 1019 W Washington St, Ann Arbor, MI 48103

Micromate/Minimate Serial No. :

UM17585

Geophone Serial No.:

UM17585

Vibration Unit
Location:

UM17585 - West side of school, next to property line between 231 and 229 Buena Visa Ave.

Maximum Peak Particle Velocity (PPV) (in/sec):

Frequency (Hz) at PPV:

UM17585

0.037 - Vertical Channel on 04-01-26 at 14:17:05

UM17585

24.0Hz

Maximum Specified PPV (in/sec):

0.20

Description of Construction Activities:

General construction activities with the intent to establish a baseline vibration level during construction. Zero (0) vibration events occurred.

Reported By: RPC, P.E.

Reviewed By: MGD, P.E.

Start March 21, 2026 07:32:05
Finish March 21, 2026 11:59:59
Number of Intervals/Interval 17.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator


Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260321073205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.




Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	23.3 Hz	32.0 Hz	16.0 Hz
Date	Mar 21, 2026	Mar 21, 2026	Mar 21, 2026
Time	11:32:05	11:32:05	11:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8
 Peak Vector Sum	0.0049 in/s at March 21, 2026 11:32:05		

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Frequency (Hz)
 + Tran x Vert ø Long

Sensor Check



Start March 21, 2026 12:02:05
Finish March 21, 2026 15:29:59
Number of Intervals/Interval 13.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator


Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260321120205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121




Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	30.1 Hz	56.9 Hz	51.2 Hz
Date	Mar 21, 2026	Mar 21, 2026	Mar 21, 2026
Time	13:02:05	12:17:05	12:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8

Peak Vector Sum 0.0034 in/s at March 21, 2026 13:02:05



Frequency (Hz)
 + Tran x Vert ø Long Sensor Check



Start March 21, 2026 15:30:30
Finish March 22, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by InstanTEL
Event File Name UM17585_20260321153030.IDFH
USB Sensor Support Disabled








Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	26.9 Hz	64.0 Hz	>100 Hz
Date	Mar 21, 2026	Mar 22, 2026	Mar 21, 2026
Time	16:45:30	00:15:30	16:00:30
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8

Peak Vector Sum 0.0033 in/s at March 21, 2026 16:45:30

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Start March 22, 2026 07:32:05
Finish March 22, 2026 11:59:59
Number of Intervals/Interval 17.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator





Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260322073205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0087 in/s	0.0059 in/s	0.0121 in/s
Zero Crossing Frequency	30.1 Hz	56.9 Hz	12.8 Hz
Date	Mar 22, 2026	Mar 22, 2026	Mar 22, 2026
Time	09:32:05	09:32:05	09:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8

Peak Vector Sum 0.0122 in/s at March 22, 2026 09:32:05



Start March 22, 2026 12:02:05
Finish March 22, 2026 15:29:59
Number of Intervals/Interval 13.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260322120205.IDFH
USB Sensor Support Disabled


Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0068 in/s	0.0059 in/s	<0.005 in/s
Zero Crossing Frequency	30.1 Hz	32.0 Hz	56.9 Hz
Date	Mar 22, 2026	Mar 22, 2026	Mar 22, 2026
Time	15:17:05	15:17:05	14:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.4	4.3	4.8




Peak Vector Sum 0.0078 in/s at March 22, 2026 15:17:05

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Frequency (Hz)
+ Tran x Vert ø Long

Sensor Check



Start March 22, 2026 15:30:29
Finish March 23, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260322153029.IDFH
USB Sensor Support Disabled





Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0087 in/s	0.0106 in/s	0.0109 in/s
Zero Crossing Frequency	36.6 Hz	42.7 Hz	36.6 Hz
Date	Mar 23, 2026	Mar 23, 2026	Mar 23, 2026
Time	07:29:59	07:29:59	07:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8

Peak Vector Sum 0.0154 in/s at March 23, 2026 07:30:29

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Start March 23, 2026 07:32:05
Finish March 23, 2026 11:59:59
Number of Intervals/Interval 17.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator





Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260323073205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0223 in/s	0.0158 in/s	0.0133 in/s
Zero Crossing Frequency	30.1 Hz	34.1 Hz	32.0 Hz
Date	Mar 23, 2026	Mar 23, 2026	Mar 23, 2026
Time	10:02:05	10:02:05	08:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8

Peak Vector Sum 0.0227 in/s at March 23, 2026 10:02:05



Start March 23, 2026 12:02:05
Finish March 23, 2026 15:29:59
Number of Intervals/Interval 13.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260323120205.IDFH
USB Sensor Support Disabled


Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0276 in/s	0.0289 in/s	0.0239 in/s
Zero Crossing Frequency	28.4 Hz	36.6 Hz	36.6 Hz
Date	Mar 23, 2026	Mar 23, 2026	Mar 23, 2026
Time	13:17:05	13:02:05	13:02:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8




Peak Vector Sum 0.0365 in/s at March 23, 2026 13:02:05

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Frequency (Hz)
+ Tran x Vert ø Long

Sensor Check



Start March 23, 2026 15:30:28
Finish March 24, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260323153028.IDFH
USB Sensor Support Disabled



Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.


Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0143 in/s	0.0149 in/s	0.0326 in/s
Zero Crossing Frequency	12.8 Hz	23.3 Hz	17.1 Hz
Date	Mar 23, 2026	Mar 23, 2026	Mar 23, 2026
Time	17:15:28	17:15:28	17:15:28
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8

Peak Vector Sum 0.0358 in/s at March 23, 2026 17:15:28



USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Sensor Check



✓ Passed



✓ Passed



✓ Passed

Start March 24, 2026 07:32:05
Finish March 24, 2026 11:59:59
Number of Intervals/Interval 17.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260324073205.IDFH
USB Sensor Support Disabled


Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0062 in/s	0.0078 in/s	0.0109 in/s
Zero Crossing Frequency	42.7 Hz	34.1 Hz	28.4 Hz
Date	Mar 24, 2026	Mar 24, 2026	Mar 24, 2026
Time	08:47:05	11:47:05	08:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8




Peak Vector Sum 0.0120 in/s at March 24, 2026 08:17:05

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Frequency (Hz)
+ Tran x Vert ø Long

Sensor Check



Start March 24, 2026 12:02:05
Finish March 24, 2026 15:29:59
Number of Intervals/Interval 13.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM17585
Model Number Micromate ISEE 11.0CB
Battery Level 3.8 volts
Unit Calibration January 30, 2026 by Instantel
Event File Name UM17585_20260324120205.IDFH
USB Sensor Support Disabled


Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0155 in/s	0.0192 in/s	0.0258 in/s
Zero Crossing Frequency	42.7 Hz	39.4 Hz	39.4 Hz
Date	Mar 24, 2026	Mar 24, 2026	Mar 24, 2026
Time	14:17:05	14:17:05	14:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.5 Hz	7.3 Hz
Overswing Ratio	4.5	4.3	4.8



Peak Vector Sum 0.0305 in/s at March 24, 2026 14:17:05

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)



Frequency (Hz)
+ Tran x Vert ø Long

Sensor Check



Histogram Start Time 15:30:28 March 24, 2026
Histogram Finish Time 07:29:59 March 25, 2026
Number of Intervals 63.97 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260324153028.IDFH

Notes



Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.007	0.005	0.011	in/s
ZC Freq	39	20	20	Hz
Date	Mar 24 /26	Mar 24 /26	Mar 24 /26	
Time	17:30:28	17:30:28	17:30:28	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.011 in/s on March 24, 2026 at 17:30:28

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 March 25, 2026
Histogram Finish Time 11:59:59 March 25, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260325073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.045	0.041	0.048	in/s
ZC Freq	32	28	47	Hz
Date	Mar 25 /26	Mar 25 /26	Mar 25 /26	
Time	08:47:05	08:47:05	08:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.055 in/s on March 25, 2026 at 08:47:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 25, 2026
Histogram Finish Time 15:29:59 March 25, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260325120205.IDFH

Notes



Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.028	0.019	0.024	in/s
ZC Freq	27	39	34	Hz
Date	Mar 25 /26	Mar 25 /26	Mar 25 /26	
Time	13:32:05	12:32:05	12:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.029 in/s on March 25, 2026 at 12:17:05

USBM RI8507 And OSMRE



Sensor Check

Histogram Start Time 15:32:05 March 25, 2026
Histogram Finish Time 07:29:59 March 26, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260325153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.011	0.005	0.009	in/s
ZC Freq	21	34	23	Hz
Date	Mar 25 /26	Mar 25 /26	Mar 25 /26	
Time	17:02:05	17:02:05	17:02:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.8	

Peak Vector Sum 0.012 in/s on March 25, 2026 at 17:02:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 March 26, 2026
Histogram Finish Time 11:59:59 March 26, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260326073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.006	0.007	0.007	in/s
ZC Freq	11	51	28	Hz
Date	Mar 26 /26	Mar 26 /26	Mar 26 /26	
Time	08:32:05	11:02:05	08:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.008 in/s on March 26, 2026 at 11:02:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 26, 2026
Histogram Finish Time 15:29:59 March 26, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260326120205.IDFH

Notes



Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.010	0.013	0.017	in/s
ZC Freq	47	47	43	Hz
Date	Mar 26 /26	Mar 26 /26	Mar 26 /26	
Time	14:47:05	13:47:05	14:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.8	

Peak Vector Sum 0.019 in/s on March 26, 2026 at 14:47:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 March 26, 2026
Histogram Finish Time 07:29:59 March 27, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260326153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.020	0.017	0.028	in/s
ZC Freq	43	39	28	Hz
Date	Mar 26 /26	Mar 26 /26	Mar 26 /26	
Time	17:17:05	17:17:05	17:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.030 in/s on March 26, 2026 at 17:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 27, 2026
Histogram Finish Time 15:29:59 March 27, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260327120205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.014	0.011	0.014	in/s
ZC Freq	30	37	32	Hz
Date	Mar 27 /26	Mar 27 /26	Mar 27 /26	
Time	13:17:05	13:17:05	13:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.8	

Peak Vector Sum 0.016 in/s on March 27, 2026 at 13:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Histogram Start Time 12:02:05 March 27, 2026
Histogram Finish Time 15:29:59 March 27, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260327120205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.014	0.011	0.014	in/s
ZC Freq	30	37	32	Hz
Date	Mar 27 /26	Mar 27 /26	Mar 27 /26	
Time	13:17:05	13:17:05	13:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.8	

Peak Vector Sum 0.016 in/s on March 27, 2026 at 13:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 March 27, 2026
Histogram Finish Time 07:29:59 March 28, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260327153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.005	0.006	0.005	in/s
ZC Freq	15	57	28	Hz
Date	Mar 27 /26	Mar 27 /26	Mar 27 /26	
Time	17:47:05	17:47:05	17:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.007 in/s on March 27, 2026 at 17:47:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 March 28, 2026
Histogram Finish Time 11:59:59 March 28, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260328073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.012	0.007	0.018	in/s
ZC Freq	39	28	15	Hz
Date	Mar 28 /26	Mar 28 /26	Mar 28 /26	
Time	11:32:05	11:32:05	11:32:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.020 in/s on March 28, 2026 at 11:32:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 28, 2026
Histogram Finish Time 15:29:59 March 28, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260328120205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.004	0.004	0.007	in/s
ZC Freq	64	64	>100	Hz
Date	Mar 28 /26	Mar 28 /26	Mar 28 /26	
Time	13:32:05	13:32:05	13:32:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.007 in/s on March 28, 2026 at 13:32:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 March 28, 2026
Histogram Finish Time 07:29:59 March 29, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260328153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.013	0.007	0.010	in/s
ZC Freq	19	22	13	Hz
Date	Mar 28 /26	Mar 28 /26	Mar 28 /26	
Time	17:17:05	17:17:05	17:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.015 in/s on March 28, 2026 at 17:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 March 29, 2026
Histogram Finish Time 11:59:59 March 29, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-0CB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260329073205.IDFH

Notes



Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.003	0.002	0.003	in/s
ZC Freq	24	>100	>100	Hz
Date	Mar 29 /26	Mar 29 /26	Mar 29 /26	
Time	09:02:05	07:47:05	09:02:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.004 in/s on March 29, 2026 at 09:02:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 29, 2026
Histogram Finish Time 15:29:59 March 29, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260329120205.IDFH

Notes



Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.010	0.011	0.013	in/s
ZC Freq	85	73	51	Hz
Date	Mar 29 /26	Mar 29 /26	Mar 29 /26	
Time	14:17:05	14:17:05	14:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.8	

Peak Vector Sum 0.016 in/s on March 29, 2026 at 14:17:05

USBM RI8507 And OSMRE



12:17:05
Mar 29 /26

15:29:59
Mar 29 /26

Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 March 29, 2026
Histogram Finish Time 07:29:59 March 30, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260329153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.008	0.007	0.012	in/s
ZC Freq	37	28	18	Hz
Date	Mar 30 /26	Mar 30 /26	Mar 30 /26	
Time	01:17:05	01:17:05	01:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.014 in/s on March 30, 2026 at 01:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 March 30, 2026
Histogram Finish Time 11:59:59 March 30, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-0CB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260330073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.020	0.020	0.014	in/s
ZC Freq	30	37	85	Hz
Date	Mar 30 /26	Mar 30 /26	Mar 30 /26	
Time	10:32:05	10:32:05	09:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.031 in/s on March 30, 2026 at 10:32:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 30, 2026
Histogram Finish Time 15:29:59 March 30, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260330120205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.004	0.005	0.006	in/s
ZC Freq	32	47	20	Hz
Date	Mar 30 /26	Mar 30 /26	Mar 30 /26	
Time	15:02:05	14:32:05	15:02:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.006 in/s on March 30, 2026 at 15:02:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 March 30, 2026
Histogram Finish Time 07:29:59 March 31, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260330153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.005	0.007	0.013	in/s
ZC Freq	47	47	<1.0	Hz
Date	Mar 31 /26	Mar 31 /26	Mar 31 /26	
Time	07:29:59	07:29:59	04:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.013 in/s on March 31, 2026 at 04:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 March 31, 2026
Histogram Finish Time 11:59:59 March 31, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260331073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.010	0.008	0.011	in/s
ZC Freq	34	39	30	Hz
Date	Mar 31 /26	Mar 31 /26	Mar 31 /26	
Time	08:47:05	11:17:05	11:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.013 in/s on March 31, 2026 at 11:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 March 31, 2026
Histogram Finish Time 15:29:59 March 31, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTEL
File Name UM17585_20260331120205.IDFH

Notes



Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.009	0.007	0.007	in/s
ZC Freq	30	32	43	Hz
Date	Mar 31 /26	Mar 31 /26	Mar 31 /26	
Time	14:17:05	13:02:05	13:02:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.010 in/s on March 31, 2026 at 14:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 March 31, 2026
Histogram Finish Time 07:29:59 April 1, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260331153205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.005	0.005	0.006	in/s
ZC Freq	51	51	19	Hz
Date	Mar 31 /26	Mar 31 /26	Mar 31 /26	
Time	17:17:05	17:17:05	17:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.7	

Peak Vector Sum 0.007 in/s on March 31, 2026 at 17:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 April 1, 2026
Histogram Finish Time 11:59:59 April 1, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-0CB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260401073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.039	0.026	0.038	in/s
ZC Freq	27	32	21	Hz
Date	Apr 1 /26	Apr 1 /26	Apr 1 /26	
Time	09:32:05	09:32:05	09:32:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.8	

Peak Vector Sum 0.043 in/s on April 1, 2026 at 09:32:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 April 1, 2026
Histogram Finish Time 15:29:59 April 1, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260401120205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.026	0.017	0.034	in/s
ZC Freq	24	30	22	Hz
Date	Apr 1 /26	Apr 1 /26	Apr 1 /26	
Time	14:17:05	14:17:05	14:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.3	4.8	

Peak Vector Sum 0.037 in/s on April 1, 2026 at 14:17:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Histogram Start Time 15:32:05 April 1, 2026
Histogram Finish Time 07:29:59 April 2, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb



Serial Number UM17585 V 11-0CB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260401153205.IDFH

Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.006	0.006	0.006	in/s
ZC Freq	>100	>100	>100	Hz
Date	Apr 2 /26	Apr 2 /26	Apr 2 /26	
Time	07:17:05	07:17:05	07:17:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.008 in/s on April 2, 2026 at 07:17:05



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 April 2, 2026
Histogram Finish Time 11:59:59 April 2, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-0CB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260402073205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.010	0.010	0.012	in/s
ZC Freq	28	28	27	Hz
Date	Apr 2 /26	Apr 2 /26	Apr 2 /26	
Time	09:47:05	10:47:05	10:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.014 in/s on April 2, 2026 at 10:47:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:05 April 2, 2026
Histogram Finish Time 15:29:59 April 2, 2026
Number of Intervals 13.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260402120205.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.016	0.009	0.015	in/s
ZC Freq	27	28	51	Hz
Date	Apr 2 /26	Apr 2 /26	Apr 2 /26	
Time	14:47:05	14:47:05	14:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.5	4.3	4.8	

Peak Vector Sum 0.020 in/s on April 2, 2026 at 14:47:05

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 15:32:05 April 2, 2026
Histogram Finish Time 07:29:59 April 3, 2026
Number of Intervals 63.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb



Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260402153205.IDFH

Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.007	0.009	0.010	in/s
ZC Freq	>100	>100	6.1	Hz
Date	Apr 2 /26	Apr 3 /26	Apr 3 /26	
Time	22:47:05	00:47:05	02:47:05	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.011 in/s on April 3, 2026 at 00:47:05



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:05 April 3, 2026
Histogram Finish Time 08:24:32 April 3, 2026
Number of Intervals 3.50 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb



Serial Number UM17585 V 11-OCB Micromate ISEE
Battery Level 3.7 Volts
Unit Calibration January 30, 2026 by InstanTel
File Name UM17585_20260403073205.IDFH

Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.033	0.024	0.034	in/s
ZC Freq	18	57	39	Hz
Date	Apr 3 /26	Apr 3 /26	Apr 3 /26	
Time	08:24:32	08:24:32	08:24:32	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.041 in/s on April 3, 2026 at 08:24:32



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 10:25:58 April 3, 2026
Histogram Finish Time 10:27:29 April 3, 2026
Number of Intervals 0.10 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/253121 Slauson Middle School.mmb

Serial Number UM17585 V 11-0CB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 30, 2026 by Instantel
File Name UM17585_20260403102558.IDFH



Notes
 Location 1019 W Washington St, Ann Arbor, MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 No. 253121

Extended Notes

	Tran	Vert	Long	
PPV	0.007	0.007	0.007	in/s
ZC Freq	34	12	16	Hz
Date	Apr 3 /26	Apr 3 /26	Apr 3 /26	
Time	10:27:29	10:27:29	10:27:29	
Sensor Check	Passed	Passed	Passed	
Frequency	7.3	7.5	7.3	Hz
Overswing Ratio	4.4	4.2	4.7	

Peak Vector Sum 0.010 in/s on April 3, 2026 at 10:27:29

USBM RI8507 And OSMRE



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check