

	Vibration Monitoring Report Summary		
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 06/22/2026 to 6/28/2026 Client Contact: Erik Bodker (Gilbane)
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103		
Micromate/Minimate Serial No. :	UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista		
Maximum Peak Particle Velocity (PPV) (in/sec):		Frequency (Hz) at PPV:	
UM16684	0.03822 - Vertical Channel on 06/22/2026 at 13:15:06	UM16684	28.4Hz
Maximum Specified PPV (in/sec):		0.20	
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.			
Reported By: RPC, P.E.		Reviewed By: MGD, P.E.	



Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 21, 2026 15:30:21
June 22, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260621153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio
Peak Vector Sum

Tran	Vert	Long
0.0143 in/s	0.0140 in/s	0.0096 in/s
>100 Hz	>100 Hz	>100 Hz
Jun 22, 2026	Jun 22, 2026	Jun 22, 2026
03:00:21	03:30:21	04:15:21
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.3 Hz
4.9	4.6	4.2

0.0169 in/s at June 22, 2026 03:00:21

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 22, 2026 07:30:06
June 22, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260622073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.



Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0062 in/s	0.0109 in/s	0.0093 in/s
39.4 Hz	46.5 Hz	46.5 Hz
Jun 22, 2026	Jun 22, 2026	Jun 22, 2026
10:45:06	10:45:06	10:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

Peak Vector Sum 0.0128 in/s at June 22, 2026 10:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 22, 2026 12:00:06
June 22, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260622120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone


Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0301 in/s	0.0382 in/s	0.0233 in/s
32.0 Hz	28.4 Hz	39.4 Hz
Jun 22, 2026	Jun 22, 2026	Jun 22, 2026
13:15:06	13:15:06	13:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum

0.0516 in/s at June 22, 2026 13:15:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 22, 2026 15:32:05
June 23, 2026 07:29:59
63.86/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260622153205.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.


Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0140 in/s	0.0254 in/s	0.0143 in/s
39.4 Hz	39.4 Hz	42.7 Hz
Jun 22, 2026	Jun 22, 2026	Jun 22, 2026
16:17:05	16:17:05	16:17:05
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.5 Hz
4.9	4.6	4.2

Peak Vector Sum 0.0267 in/s at June 22, 2026 16:17:05

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 23, 2026 07:30:06
June 23, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260623073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0192 in/s	0.0127 in/s	0.0323 in/s
32.0 Hz	34.1 Hz	23.3 Hz
Jun 23, 2026	Jun 23, 2026	Jun 23, 2026
11:59:59	11:59:59	11:59:59
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0335 in/s at June 23, 2026 12:00:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 23, 2026 12:00:06
June 23, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260623120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0112 in/s	0.0140 in/s	0.0121 in/s
36.6 Hz	51.2 Hz	56.9 Hz
Jun 23, 2026	Jun 23, 2026	Jun 23, 2026
13:30:06	13:30:06	13:00:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0157 in/s at June 23, 2026 13:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 23, 2026 15:30:25
June 24, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260623153025.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.





Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0118 in/s	0.0118 in/s	0.0068 in/s
36.6 Hz	24.4 Hz	26.9 Hz
Jun 24, 2026 07:29:59	Jun 24, 2026 07:29:59	Jun 24, 2026 07:29:59
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.6	4.2

Peak Vector Sum 0.0136 in/s at June 24, 2026 07:30:25

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 24, 2026 07:30:06
June 24, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260624073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0071 in/s	0.0102 in/s	0.0059 in/s
34.1 Hz	39.4 Hz	46.5 Hz
Jun 24, 2026	Jun 24, 2026	Jun 24, 2026
08:00:06	09:15:06	09:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0117 in/s at June 24, 2026 09:15:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 24, 2026 12:00:06
June 24, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260624120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0084 in/s	0.0081 in/s	0.0059 in/s
32.0 Hz	24.4 Hz	26.9 Hz
Jun 24, 2026	Jun 24, 2026	Jun 24, 2026
14:00:06	14:00:06	13:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0091 in/s at June 24, 2026 13:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 24, 2026 15:30:20
June 25, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260624153020.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.


Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0168 in/s	0.0106 in/s	0.0090 in/s
>100 Hz	>100 Hz	>100 Hz
Jun 25, 2026	Jun 25, 2026	Jun 25, 2026
01:30:20	01:15:20	01:00:20
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

Peak Vector Sum 0.0186 in/s at June 25, 2026 01:30:20

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 25, 2026 07:30:06
June 25, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260625073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.


Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0084 in/s	0.0137 in/s	0.0081 in/s
>100 Hz	42.7 Hz	39.4 Hz
Jun 25, 2026	Jun 25, 2026	Jun 25, 2026
10:45:06	08:30:06	08:30:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.0149 in/s at June 25, 2026 08:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 25, 2026 12:00:06
June 25, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260625120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.



Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0056 in/s	<0.005 in/s
36.6 Hz	39.4 Hz	73.1 Hz
Jun 25, 2026	Jun 25, 2026	Jun 25, 2026
13:45:06	14:30:06	12:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0064 in/s at June 25, 2026 14:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 25, 2026 15:30:21
June 26, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260625153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.





Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0087 in/s	0.0065 in/s	0.0053 in/s
30.1 Hz	24.4 Hz	34.1 Hz
Jun 26, 2026	Jun 26, 2026	Jun 26, 2026
07:15:21	07:15:21	07:29:59
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.6	4.2

Peak Vector Sum 0.0089 in/s at June 26, 2026 07:15:21

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 26, 2026 07:30:06
June 26, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260626073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0059 in/s
30.1 Hz
Jun 26, 2026
09:30:06
✓ Passed
7.1 Hz
4.8

Vert

0.0059 in/s
26.9 Hz
Jun 26, 2026
10:15:06
✓ Passed
7.3 Hz
4.5





Long

0.0056 in/s
30.1 Hz
Jun 26, 2026
10:30:06
✓ Passed
7.3 Hz
4.2

Peak Vector Sum

0.0073 in/s at June 26, 2026 09:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 26, 2026 12:00:06
June 26, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260626120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0056 in/s	0.0065 in/s	0.0062 in/s
42.7 Hz	39.4 Hz	34.1 Hz
Jun 26, 2026	Jun 26, 2026	Jun 26, 2026
14:00:06	14:15:06	12:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0074 in/s at June 26, 2026 14:00:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 26, 2026 15:30:22
June 27, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260626153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.





Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0093 in/s	0.0112 in/s	0.0062 in/s
34.1 Hz	30.1 Hz	28.4 Hz
Jun 26, 2026	Jun 26, 2026	Jun 26, 2026
16:30:22	16:15:22	16:15:22
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

Peak Vector Sum 0.0138 in/s at June 26, 2026 16:15:22

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 27, 2026 07:30:06
June 27, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260627073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
42.7 Hz	36.6 Hz	3.2 Hz
Jun 27, 2026	Jun 27, 2026	Jun 27, 2026
09:15:06	07:45:06	09:00:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0044 in/s at June 27, 2026 09:15:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 27, 2026 12:00:06
June 27, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260627120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
46.5 Hz	22.3 Hz	1.7 Hz
Jun 27, 2026	Jun 27, 2026	Jun 27, 2026
12:45:06	15:29:59	12:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.4	4.1

Peak Vector Sum 0.0044 in/s at June 27, 2026 15:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 27, 2026 15:30:21
June 28, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260627153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes


1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio
Peak Vector Sum

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
>100 Hz	21.3 Hz	17.7 Hz
Jun 27, 2026	Jun 27, 2026	Jun 27, 2026
19:00:21	15:45:21	15:45:21
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

0.0043 in/s at June 27, 2026 15:45:21





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 28, 2026 07:30:06
June 28, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260628073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
85.3 Hz	20.5 Hz	34.1 Hz
Jun 28, 2026	Jun 28, 2026	Jun 28, 2026
07:45:06	07:45:06	11:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0038 in/s at June 28, 2026 07:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 28, 2026 12:00:06
June 28, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260628120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes



1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
64.0 Hz	64.0 Hz	2.1 Hz
Jun 28, 2026	Jun 28, 2026	Jun 28, 2026
13:00:06	12:15:06	12:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0041 in/s at June 28, 2026 12:30:06





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

June 28, 2026 15:30:22
June 29, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260628153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0065 in/s	0.0056 in/s
30.1 Hz	30.1 Hz	32.0 Hz
Jun 29, 2026	Jun 29, 2026	Jun 29, 2026
07:15:22	07:15:22	07:15:22
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

Peak Vector Sum 0.0070 in/s at June 29, 2026 07:15:22

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)

