

	Vibration Monitoring Report Summary			
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 07/06/2026 to 7/12/2026 Client Contact: Erik Bodker (Gilbane)	
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103			
Micromate/Minimate Serial No. :		UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista			
Maximum Peak Particle Velocity (PPV) (in/sec):			Frequency (Hz) at PPV:	
UM16684	0.0400 - Vertical Channel on 07/07/2026 at 07:17:05		UM16684	34.1Hz
Maximum Specified PPV (in/sec): 0.20				
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.				
Reported By: RPC, P.E.			Reviewed By: MGD, P.E.	



Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 6, 2026 07:30:06
July 6, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260706073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0068 in/s
39.4 Hz
Jul 6, 2026
10:30:06
✓ Passed
7.1 Hz
4.8

Vert



0.0081 in/s
56.9 Hz
Jul 6, 2026
10:30:06
✓ Passed
7.3 Hz
4.5

Long

0.0078 in/s
>100 Hz
Jul 6, 2026
09:15:06
✓ Passed
7.3 Hz
4.1

Peak Vector Sum 0.0086 in/s at July 6, 2026 10:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)







Start July 6, 2026 12:00:06
Finish July 6, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260706120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0106 in/s	0.0093 in/s	0.0115 in/s
Zero Crossing Frequency	32.0 Hz	34.1 Hz	42.7 Hz
Date	Jul 6, 2026	Jul 6, 2026	Jul 6, 2026
Time	12:45:06	12:45:06	12:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0153 in/s at July 6, 2026 12:45:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 6, 2026 15:32:05
July 7, 2026 07:29:59
63.86/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260706153205.IDFH
Disabled

Notes
Location
Client
Company
General Notes



1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio
Peak Vector Sum

Tran	Vert	Long
0.0400 in/s	0.0168 in/s	0.0289 in/s
34.1 Hz	39.4 Hz	39.4 Hz
Jul 7, 2026	Jul 7, 2026	Jul 7, 2026
07:17:05	07:17:05	07:17:05
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

0.0482 in/s at July 7, 2026 07:17:05





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 7, 2026 07:30:06
July 7, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260707073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0078 in/s	0.0124 in/s	0.0081 in/s
56.9 Hz	85.3 Hz	42.7 Hz
Jul 7, 2026	Jul 7, 2026	Jul 7, 2026
10:15:06	11:30:06	10:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0133 in/s at July 7, 2026 11:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)







Start July 7, 2026 12:00:06
Finish July 7, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260707120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0106 in/s	0.0068 in/s	0.0059 in/s
Zero Crossing Frequency	36.6 Hz	42.7 Hz	28.4 Hz
Date	Jul 7, 2026	Jul 7, 2026	Jul 7, 2026
Time	14:15:06	14:45:06	13:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0122 in/s at July 7, 2026 14:15:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 7, 2026 15:32:05
July 8, 2026 07:29:59
63.86/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260707153205.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.





Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0053 in/s	<0.005 in/s
36.6 Hz	85.3 Hz	32.0 Hz
Jul 8, 2026	Jul 8, 2026	Jul 8, 2026
07:17:05	07:17:05	07:29:59
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0053 in/s at July 8, 2026 07:17:05

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 8, 2026 07:30:06
July 8, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260708073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0124 in/s	0.0074 in/s	0.0084 in/s
>100 Hz	39.4 Hz	>100 Hz
Jul 8, 2026	Jul 8, 2026	Jul 8, 2026
08:30:06	11:45:06	08:30:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0134 in/s at July 8, 2026 08:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 8, 2026 12:00:06
July 8, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260708120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0062 in/s	0.0071 in/s	0.0053 in/s
39.4 Hz	46.5 Hz	34.1 Hz
Jul 8, 2026	Jul 8, 2026	Jul 8, 2026
13:30:06	13:30:06	13:30:06
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0076 in/s at July 8, 2026 13:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 8, 2026 15:31:00
July 9, 2026 07:29:59
63.93/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260708153100.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0161 in/s	0.0106 in/s	0.0087 in/s
36.6 Hz	42.7 Hz	46.5 Hz
Jul 9, 2026	Jul 9, 2026	Jul 9, 2026
07:16:00	07:16:00	07:16:00
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0177 in/s at July 9, 2026 07:16:00

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 9, 2026 07:30:06
July 9, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260709073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0056 in/s	0.0053 in/s	0.0059 in/s
39.4 Hz	26.9 Hz	28.4 Hz
Jul 9, 2026	Jul 9, 2026	Jul 9, 2026
11:00:06	09:00:06	11:00:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.4	4.1

Peak Vector Sum 0.0068 in/s at July 9, 2026 11:00:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 9, 2026 12:00:06
July 9, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260709120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0109 in/s	0.0121 in/s	0.0161 in/s
>100 Hz	>100 Hz	26.9 Hz
Jul 9, 2026	Jul 9, 2026	Jul 9, 2026
14:15:06	14:15:06	12:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0180 in/s at July 9, 2026 12:15:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 9, 2026 15:30:22
July 10, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260709153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0056 in/s
>100 Hz
Jul 9, 2026
16:00:22
✓ Passed
7.1 Hz
4.8

Vert

0.0053 in/s
23.3 Hz
Jul 10, 2026
07:29:59
✓ Passed
7.3 Hz
4.5





Long

0.0056 in/s
<1 Hz
Jul 9, 2026
17:45:22
✓ Passed
7.3 Hz
4.1

Peak Vector Sum

0.0066 in/s at July 9, 2026 16:00:22

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 10, 2026 07:30:06
July 10, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260710073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0065 in/s
28.4 Hz
Jul 10, 2026
07:45:06
✓ Passed
7.1 Hz
4.8

Vert

0.0062 in/s
28.4 Hz
Jul 10, 2026
07:45:06
✓ Passed
7.3 Hz
4.5



Long

<0.005 in/s
30.1 Hz
Jul 10, 2026
07:45:06
✓ Passed
7.3 Hz
4.1

Peak Vector Sum

0.0082 in/s at July 10, 2026 07:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 10, 2026 12:00:06
July 10, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260710120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0074 in/s	0.0062 in/s	<0.005 in/s
42.7 Hz	51.2 Hz	39.4 Hz
Jul 10, 2026	Jul 10, 2026	Jul 10, 2026
13:45:06	13:45:06	13:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0084 in/s at July 10, 2026 13:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 10, 2026 15:30:21
July 11, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260710153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0065 in/s	0.0071 in/s
>100 Hz	>100 Hz	>100 Hz
Jul 10, 2026	Jul 10, 2026	Jul 10, 2026
17:45:21	17:45:21	17:45:21
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.5 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0075 in/s at July 10, 2026 17:45:21

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 11, 2026 07:30:06
July 11, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260711073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes





1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
23.3 Hz	85.3 Hz	1.5 Hz
Jul 11, 2026	Jul 11, 2026	Jul 11, 2026
07:45:06	07:45:06	07:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0040 in/s at July 11, 2026 07:45:06





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 11, 2026 12:00:06
July 11, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260711120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes



1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0081 in/s	<0.005 in/s	0.0068 in/s
56.9 Hz	64.0 Hz	51.2 Hz
Jul 11, 2026	Jul 11, 2026	Jul 11, 2026
14:30:06	14:30:06	14:30:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0083 in/s at July 11, 2026 14:30:06





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 11, 2026 15:30:21
July 12, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260711153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
51.2 Hz	>100 Hz	1.3 Hz
Jul 12, 2026	Jul 11, 2026	Jul 11, 2026
05:15:21	17:45:21	22:00:21
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0039 in/s at July 12, 2026 01:00:21

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 12, 2026 07:30:06
July 12, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260712073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

<0.005 in/s
56.9 Hz
Jul 12, 2026
07:45:06
✓ Passed
7.1 Hz
4.8

Vert

<0.005 in/s
46.5 Hz
Jul 12, 2026
07:45:06
✓ Passed
7.3 Hz
4.5



Long

<0.005 in/s
36.6 Hz
Jul 12, 2026
11:59:59
✓ Passed
7.3 Hz
4.1

Peak Vector Sum

0.0037 in/s at July 12, 2026 10:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 12, 2026 12:00:06
July 12, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260712120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
64.0 Hz	>100 Hz	<1 Hz
Jul 12, 2026	Jul 12, 2026	Jul 12, 2026
14:15:06	12:15:06	14:30:06
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0041 in/s at July 12, 2026 14:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 12, 2026 15:30:22
July 13, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260712153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0053 in/s	<0.005 in/s
42.7 Hz	19.0 Hz	1.1 Hz
Jul 13, 2026	Jul 13, 2026	Jul 13, 2026
07:29:59	07:29:59	07:00:22
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.0056 in/s at July 13, 2026 07:30:22

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 12, 2026 15:30:22
July 13, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260712153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0053 in/s	<0.005 in/s
42.7 Hz	19.0 Hz	1.1 Hz
Jul 13, 2026	Jul 13, 2026	Jul 13, 2026
07:29:59	07:29:59	07:00:22
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.0056 in/s at July 13, 2026 07:30:22

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)

