

	Vibration Monitoring Report Summary			
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 07/20/2026 to 7/26/2026 Client Contact: Erik Bodker (Gilbane)	
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103			
Micromate/Minimate Serial No. :		UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista			
Maximum Peak Particle Velocity (PPV) (in/sec):			Frequency (Hz) at PPV:	
UM16684	0.1095 - Transverse Channel on 07/22/2026 at 09:30:06		UM16684	>100Hz
Maximum Specified PPV (in/sec): 0.20				
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.				
Reported By: RPC, P.E.			Reviewed By: MGD, P.E.	



Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 26, 2026 07:30:06
July 26, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260726073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
>100 Hz	>100 Hz	32.0 Hz
Jul 26, 2026	Jul 26, 2026	Jul 26, 2026
07:45:06	07:45:06	07:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.0032 in/s at July 26, 2026 07:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 25, 2026 15:30:21
July 26, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260725153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
64.0 Hz	>100 Hz	6.6 Hz
Jul 26, 2026	Jul 25, 2026	Jul 25, 2026
05:00:21	17:45:21	19:45:21
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

Peak Vector Sum 0.0034 in/s at July 26, 2026 02:00:21

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 25, 2026 12:00:06
July 25, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260725120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
>100 Hz	>100 Hz	5.2 Hz
Jul 25, 2026	Jul 25, 2026	Jul 25, 2026
12:30:06	12:15:06	12:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.4	4.1

Peak Vector Sum 0.0034 in/s at July 25, 2026 12:15:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 25, 2026 07:30:06
July 25, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260725073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes



1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
5.3 Hz	73.1 Hz	3.6 Hz
Jul 25, 2026	Jul 25, 2026	Jul 25, 2026
07:45:06	07:45:06	07:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.0041 in/s at July 25, 2026 07:45:06





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 24, 2026 15:30:21
July 25, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260724153021.IDFH
Disabled

Notes
Location
Client
Company
General Notes


1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio
Peak Vector Sum

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
56.9 Hz	>100 Hz	6.7 Hz
Jul 24, 2026	Jul 24, 2026	Jul 24, 2026
18:00:21	18:45:21	16:00:21
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.5	4.2

0.0034 in/s at July 24, 2026 16:00:21





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 24, 2026 12:00:06
July 24, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260724120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0093 in/s
51.2 Hz
Jul 24, 2026
13:30:06
✓ Passed
7.1 Hz
4.8

Vert

0.0118 in/s
39.4 Hz
Jul 24, 2026
13:30:06
✓ Passed
7.3 Hz
4.5


Long

0.0137 in/s
26.9 Hz
Jul 24, 2026
13:30:06
✓ Passed
7.3 Hz
4.1

Peak Vector Sum

0.0163 in/s at July 24, 2026 13:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 24, 2026 07:30:06
July 24, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260724073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0096 in/s	0.0177 in/s	0.0074 in/s
64.0 Hz	64.0 Hz	20.5 Hz
Jul 24, 2026	Jul 24, 2026	Jul 24, 2026
09:30:06	09:30:06	08:15:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.0203 in/s at July 24, 2026 09:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 23, 2026 15:30:22
July 24, 2026 07:29:59
63.97/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260723153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0056 in/s	0.0084 in/s	0.0065 in/s
64.0 Hz	64.0 Hz	56.9 Hz
Jul 24, 2026	Jul 24, 2026	Jul 24, 2026
07:00:22	07:00:22	07:00:22
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.6	4.2

Peak Vector Sum 0.0103 in/s at July 24, 2026 07:00:22

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 23, 2026 12:00:06
July 23, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260723120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes





1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0341 in/s	0.0338 in/s	0.0307 in/s
26.9 Hz	25.6 Hz	36.6 Hz
Jul 23, 2026	Jul 23, 2026	Jul 23, 2026
14:30:06	14:45:06	14:45:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0400 in/s at July 23, 2026 14:30:06





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 23, 2026 07:30:06
July 23, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260723073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

<0.005 in/s
32.0 Hz
Jul 23, 2026
11:00:06
✓ Passed
7.1 Hz
4.8

Vert





<0.005 in/s
73.1 Hz
Jul 23, 2026
08:00:06
✓ Passed
7.3 Hz
4.5

Long

0.0081 in/s
56.9 Hz
Jul 23, 2026
11:59:59
✓ Passed
7.3 Hz
4.2

Peak Vector Sum 0.0081 in/s at July 23, 2026 12:00:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 22, 2026 15:30:22
July 23, 2026 07:29:59
63.98/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260722153022.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0059 in/s	0.0056 in/s
56.9 Hz	64.0 Hz	56.9 Hz
Jul 23, 2026	Jul 23, 2026	Jul 23, 2026
07:15:22	07:15:22	07:15:22
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.9	4.6	4.2

Peak Vector Sum 0.0070 in/s at July 23, 2026 07:15:22

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 22, 2026 12:00:06
July 22, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260722120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0186 in/s
46.5 Hz
Jul 22, 2026
13:45:06
✓ Passed
7.1 Hz
4.8

Vert

0.0093 in/s
23.3 Hz
Jul 22, 2026
13:30:06
✓ Passed
7.3 Hz
4.4





Long

0.0189 in/s
56.9 Hz
Jul 22, 2026
13:45:06
✓ Passed
7.3 Hz
4.1

Peak Vector Sum

0.0266 in/s at July 22, 2026 13:45:06

USBM R18507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 22, 2026 07:30:06
July 22, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260722073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.1095 in/s
>100 Hz
Jul 22, 2026
09:30:06
✓ Passed
7.1 Hz
4.8

Vert

0.0825 in/s
>100 Hz
Jul 22, 2026
09:30:06
✓ Passed
7.3 Hz
4.5





Long

0.0537 in/s
>100 Hz
Jul 22, 2026
09:30:06
✓ Passed
7.3 Hz
4.2

Peak Vector Sum

0.1386 in/s at July 22, 2026 09:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 21, 2026 15:30:55
July 22, 2026 07:29:59
63.94/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support


UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260721153055.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	32.0 Hz	>100 Hz	23.3 Hz
Date	Jul 22, 2026	Jul 22, 2026	Jul 22, 2026
Time	07:15:55	00:00:55	07:00:55
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.6	4.2
Peak Vector Sum	0.0044 in/s at July 22, 2026 07:15:55		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 21, 2026 12:00:06
July 21, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260721120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121



Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.0062 in/s	0.0081 in/s	<0.005 in/s
>100 Hz	85.3 Hz	85.3 Hz
Jul 21, 2026	Jul 21, 2026	Jul 21, 2026
14:30:06	14:30:06	12:30:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.7	4.4	4.1

Peak Vector Sum 0.0085 in/s at July 21, 2026 14:30:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 20, 2026 15:32:05
July 21, 2026 07:29:59
63.86/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260720153205.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	<0.005 in/s	<0.005 in/s
56.9 Hz	64.0 Hz	6.2 Hz
Jul 20, 2026	Jul 21, 2026	Jul 20, 2026
21:47:05	07:02:05	16:47:05
✓ Passed	✓ Passed	✓ Passed
7.3 Hz	7.3 Hz	7.5 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0041 in/s at July 21, 2026 06:47:05

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 20, 2026 12:00:06
July 20, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260720120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone

Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran

0.0053 in/s
51.2 Hz
Jul 20, 2026
14:45:06
✓ Passed
7.1 Hz
4.7

Vert

0.0056 in/s
39.4 Hz
Jul 20, 2026
14:00:06
✓ Passed
7.3 Hz
4.4


Long

<0.005 in/s
>100 Hz
Jul 20, 2026
13:30:06
✓ Passed
7.3 Hz
4.1

Peak Vector Sum

0.0073 in/s at July 20, 2026 14:45:06

USBM RI8507 And OSMRE
Velocity versus Frequency (Zero Crossing)





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

July 20, 2026 07:30:06
July 20, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260720073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
<0.005 in/s	0.0065 in/s	0.0062 in/s
16.5 Hz	25.6 Hz	22.3 Hz
Jul 20, 2026	Jul 20, 2026	Jul 20, 2026
09:15:06	08:30:06	08:30:06
✓ Passed	✓ Passed	✓ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.1

Peak Vector Sum 0.0091 in/s at July 20, 2026 08:30:06

