

	Vibration Monitoring Report Summary		
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 08/03/2026 to 8/09/2026 Client Contact: Erik Bodker (Gilbane)
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103		
Micromate/Minimate Serial No. :	UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista		
Maximum Peak Particle Velocity (PPV) (in/sec):		Frequency (Hz) at PPV:	
UM16684	0..1142 - Transverse Channel on 08/07/2026 at 10:30:06	UM16684	7.1Hz
Maximum Specified PPV (in/sec):		0.20	
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.			
Reported By: RPC, P.E.		Reviewed By: MGD, P.E.	







Start August 3, 2026 07:30:06
Finish August 3, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260803073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0062 in/s	0.0093 in/s	0.0078 in/s
Zero Crossing Frequency	>100 Hz	51.2 Hz	56.9 Hz
Date	Aug 3, 2026	Aug 3, 2026	Aug 3, 2026
Time	07:45:06	10:15:06	10:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0119 in/s at August 3, 2026 10:15:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

August 3, 2026 12:00:06
August 3, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260803120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	0.0053 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	64.0 Hz	51.2 Hz
Date	Aug 3, 2026	Aug 3, 2026	Aug 3, 2026
Time	12:30:06	12:45:06	13:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0055 in/s at August 3, 2026 12:45:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

August 3, 2026 15:31:04
August 4, 2026 07:29:59
63.93/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260803153104.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	4.4 Hz
Date	Aug 4, 2026	Aug 4, 2026	Aug 3, 2026
Time	03:31:04	00:31:04	22:46:04
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0037 in/s at August 4, 2026 03:16:04		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

August 4, 2026 07:30:06
August 4, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260804073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0056 in/s	0.0074 in/s	0.0099 in/s
Zero Crossing Frequency	56.9 Hz	73.1 Hz	56.9 Hz
Date	Aug 4, 2026	Aug 4, 2026	Aug 4, 2026
Time	08:15:06	08:15:06	08:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0108 in/s at August 4, 2026 08:15:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

August 4, 2026 12:00:06
August 4, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260804120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0074 in/s	0.0074 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	56.9 Hz
Date	Aug 4, 2026	Aug 4, 2026	Aug 4, 2026
Time	12:15:06	12:15:06	13:00:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0084 in/s at August 4, 2026 12:15:06		









Start August 4, 2026 15:32:05
Finish August 5, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260804153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0155 in/s	0.0199 in/s	0.0233 in/s
Zero Crossing Frequency	56.9 Hz	56.9 Hz	56.9 Hz
Date	Aug 5, 2026	Aug 5, 2026	Aug 5, 2026
Time	06:32:05	06:32:05	06:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0317 in/s at August 5, 2026 06:32:05		









Start August 5, 2026 07:30:06
Finish August 5, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260805073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0186 in/s	0.0217 in/s	0.0254 in/s
Zero Crossing Frequency	11.1 Hz	17.7 Hz	12.5 Hz
Date	Aug 5, 2026	Aug 5, 2026	Aug 5, 2026
Time	11:15:06	11:00:06	11:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0314 in/s at August 5, 2026 11:15:06		









Start August 5, 2026 12:00:06
Finish August 5, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260805120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0096 in/s	0.0106 in/s	0.0068 in/s
Zero Crossing Frequency	18.3 Hz	12.5 Hz	13.1 Hz
Date	Aug 5, 2026	Aug 5, 2026	Aug 5, 2026
Time	15:29:59	15:00:06	15:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0114 in/s at August 5, 2026 15:00:06		









Start August 5, 2026 15:32:05
Finish August 6, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260805153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0109 in/s	0.0071 in/s	0.0137 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Aug 6, 2026	Aug 6, 2026	Aug 6, 2026
Time	02:47:05	02:32:05	02:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0153 in/s at August 6, 2026 02:32:05		









Start August 6, 2026 07:30:06
Finish August 6, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260806073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0388 in/s	0.0236 in/s	0.0146 in/s
Zero Crossing Frequency	39.4 Hz	36.6 Hz	34.1 Hz
Date	Aug 6, 2026	Aug 6, 2026	Aug 6, 2026
Time	10:15:06	10:15:06	10:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0421 in/s at August 6, 2026 10:15:06		









Start August 6, 2026 12:00:06
Finish August 6, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260806120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	85.3 Hz	7.0 Hz
Date	Aug 6, 2026	Aug 6, 2026	Aug 6, 2026
Time	13:30:06	13:45:06	12:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0040 in/s at August 6, 2026 13:30:06		







Start August 6, 2026 15:30:30
Finish August 7, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260806153030.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	51.2 Hz	64.0 Hz	3.8 Hz
Date	Aug 7, 2026	Aug 7, 2026	Aug 7, 2026
Time	07:29:59	07:29:59	06:00:30
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0042 in/s at August 7, 2026 06:00:30		








Start August 7, 2026 07:30:06
Finish August 7, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260807073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.1142 in/s	0.0202 in/s	0.0999 in/s
Zero Crossing Frequency	17.7 Hz	19.7 Hz	19.0 Hz
Date	Aug 7, 2026	Aug 7, 2026	Aug 7, 2026
Time	10:30:06	10:30:06	10:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.1146 in/s at August 7, 2026 10:30:06		









Start August 7, 2026 12:00:06
Finish August 7, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260807120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0062 in/s	0.0090 in/s	0.0074 in/s
Zero Crossing Frequency	>100 Hz	64.0 Hz	64.0 Hz
Date	Aug 7, 2026	Aug 7, 2026	Aug 7, 2026
Time	13:15:06	13:15:06	13:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0116 in/s at August 7, 2026 13:15:06		






Start August 7, 2026 15:30:23
Finish August 8, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260807153023.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	14.6 Hz	4.3 Hz
Date	Aug 8, 2026	Aug 7, 2026	Aug 7, 2026
Time	00:30:23	20:45:23	22:30:23
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0041 in/s at August 7, 2026 22:30:23		









Start August 8, 2026 07:30:06
Finish August 8, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260808073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	64.0 Hz	6.6 Hz
Date	Aug 8, 2026	Aug 8, 2026	Aug 8, 2026
Time	07:45:06	07:45:06	09:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0037 in/s at August 8, 2026 09:30:06		









Start August 8, 2026 12:00:06
Finish August 8, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260808120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	21.3 Hz
Date	Aug 8, 2026	Aug 8, 2026	Aug 8, 2026
Time	12:15:06	12:30:06	13:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0035 in/s at August 8, 2026 13:15:06		









Start August 8, 2026 15:30:23
Finish August 9, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260808153023.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	56.9 Hz	>100 Hz	15.5 Hz
Date	Aug 8, 2026	Aug 8, 2026	Aug 8, 2026
Time	23:15:23	22:00:23	19:15:23
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0038 in/s at August 8, 2026 19:15:23		









Start August 9, 2026 07:30:06
Finish August 9, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260809073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	85.3 Hz	11.1 Hz
Date	Aug 9, 2026	Aug 9, 2026	Aug 9, 2026
Time	08:15:06	07:45:06	10:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0035 in/s at August 9, 2026 10:15:06		









Start August 9, 2026 12:00:06
Finish August 9, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260809120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	51.2 Hz	17.7 Hz
Date	Aug 9, 2026	Aug 9, 2026	Aug 9, 2026
Time	12:15:06	12:15:06	12:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0036 in/s at August 9, 2026 12:30:06		





Start August 9, 2026 15:30:20
Finish August 10, 2026 07:29:59
Number of Intervals/Interval 63.98/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260809153020.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0130 in/s	<0.005 in/s	0.0137 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Aug 10, 2026	Aug 10, 2026	Aug 10, 2026
Time	06:30:20	05:45:20	07:15:20
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0171 in/s at August 10, 2026 06:30:20		

