

	Vibration Monitoring Report Summary		
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 09/07/2026 to 9/13/2026 Client Contact: Erik Bodker (Gilbane)
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103		
Micromate/Minimate Serial No. :	UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista		
Maximum Peak Particle Velocity (PPV) (in/sec):		Frequency (Hz) at PPV:	
UM16684	0.0208 - Longitudinal Channel on 09/11/2026 at 11:15:06	UM16684	64.0 Hz
Maximum Specified PPV (in/sec):		0.20	
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.			
Reported By: RPC, P.E.		Reviewed By: MGD, P.E.	







Start September 7, 2026 07:30:06
Finish September 7, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260907073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	18.3 Hz	1.6 Hz
Date	Sep 7, 2026	Sep 7, 2026	Sep 7, 2026
Time	11:59:59	08:15:06	09:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0037 in/s at September 7, 2026 08:15:06		









Start September 7, 2026 12:00:06
Finish September 7, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260907120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	0.0062 in/s	0.0068 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 7, 2026	Sep 7, 2026	Sep 7, 2026
Time	15:29:59	15:29:59	15:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0075 in/s at September 7, 2026 15:30:06		






Start September 7, 2026 15:30:40
Finish September 8, 2026 07:29:59
Number of Intervals/Interval 63.95/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260907153040.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	51.2 Hz	>100 Hz	42.7 Hz
Date	Sep 8, 2026	Sep 7, 2026	Sep 8, 2026
Time	06:30:40	17:15:40	07:15:40
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0054 in/s at September 8, 2026 07:15:40		









Start September 8, 2026 07:30:06
Finish September 8, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260908073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0081 in/s	0.0074 in/s	0.0084 in/s
Zero Crossing Frequency	36.6 Hz	15.5 Hz	85.3 Hz
Date	Sep 8, 2026	Sep 8, 2026	Sep 8, 2026
Time	09:15:06	09:15:06	11:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0099 in/s at September 8, 2026 09:15:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 8, 2026 12:00:06
September 8, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260908120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0059 in/s	<0.005 in/s	0.0062 in/s
Zero Crossing Frequency	42.7 Hz	25.6 Hz	34.1 Hz
Date	Sep 8, 2026	Sep 8, 2026	Sep 8, 2026
Time	12:15:06	12:15:06	12:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0081 in/s at September 8, 2026 12:15:06		






Start September 8, 2026 15:30:21
Finish September 9, 2026 07:29:59
Number of Intervals/Interval 63.98/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260908153021.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0109 in/s	0.0102 in/s	0.0146 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 9, 2026	Sep 9, 2026	Sep 9, 2026
Time	02:45:21	03:00:21	02:45:21
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0162 in/s at September 9, 2026 02:45:21		









Start September 9, 2026 07:30:06
Finish September 9, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260909073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0109 in/s	0.0074 in/s	0.0112 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 9, 2026	Sep 9, 2026	Sep 9, 2026
Time	11:45:06	11:45:06	11:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0137 in/s at September 9, 2026 11:45:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 9, 2026 12:00:06
September 9, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260909120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0106 in/s	0.0081 in/s	0.0109 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 9, 2026	Sep 9, 2026	Sep 9, 2026
Time	12:15:06	12:15:06	12:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0129 in/s at September 9, 2026 14:00:06		









Start September 9, 2026 15:32:05
Finish September 10, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260909153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0099 in/s	0.0071 in/s	0.0084 in/s
Zero Crossing Frequency	36.6 Hz	51.2 Hz	36.6 Hz
Date	Sep 10, 2026	Sep 10, 2026	Sep 10, 2026
Time	07:02:05	07:02:05	07:02:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0126 in/s at September 10, 2026 07:02:05		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 10, 2026 07:30:06
September 10, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260910073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0081 in/s	0.0056 in/s	0.0074 in/s
Zero Crossing Frequency	42.7 Hz	46.5 Hz	36.6 Hz
Date	Sep 10, 2026	Sep 10, 2026	Sep 10, 2026
Time	09:45:06	09:45:06	09:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0112 in/s at September 10, 2026 09:45:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 10, 2026 12:00:06
September 10, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260910120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0071 in/s	0.0106 in/s	0.0158 in/s
Zero Crossing Frequency	42.7 Hz	64.0 Hz	64.0 Hz
Date	Sep 10, 2026	Sep 10, 2026	Sep 10, 2026
Time	13:00:06	12:45:06	12:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0171 in/s at September 10, 2026 12:45:06		









Start September 10, 2026 15:30:25
Finish September 11, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260910153025.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	0.0065 in/s	0.0056 in/s
Zero Crossing Frequency	46.5 Hz	73.1 Hz	39.4 Hz
Date	Sep 10, 2026	Sep 10, 2026	Sep 11, 2026
Time	17:15:25	17:00:25	07:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.6	4.2
Peak Vector Sum	0.0078 in/s at September 10, 2026 17:00:25		









Start September 11, 2026 07:30:06
Finish September 11, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260911073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0152 in/s	0.0106 in/s	0.0208 in/s
Zero Crossing Frequency	42.7 Hz	73.1 Hz	64.0 Hz
Date	Sep 11, 2026	Sep 11, 2026	Sep 11, 2026
Time	10:45:06	11:00:06	11:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0209 in/s at September 11, 2026 11:15:06		









Start September 11, 2026 12:00:06
Finish September 11, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260911120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0115 in/s	0.0109 in/s	0.0087 in/s
Zero Crossing Frequency	46.5 Hz	56.9 Hz	46.5 Hz
Date	Sep 11, 2026	Sep 11, 2026	Sep 11, 2026
Time	12:45:06	12:45:06	12:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0179 in/s at September 11, 2026 12:45:06		






Start September 11, 2026 15:30:20
Finish September 12, 2026 07:29:59
Number of Intervals/Interval 63.98/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260911153020.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	0.0053 in/s
Zero Crossing Frequency	>100 Hz	36.6 Hz	<1 Hz
Date	Sep 11, 2026	Sep 12, 2026	Sep 11, 2026
Time	16:30:20	00:00:20	19:15:20
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0053 in/s at September 11, 2026 19:15:20		









Start September 12, 2026 07:30:06
Finish September 12, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260912073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	85.3 Hz	>100 Hz	1.8 Hz
Date	Sep 12, 2026	Sep 12, 2026	Sep 12, 2026
Time	09:15:06	07:45:06	11:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0032 in/s at September 12, 2026 11:00:06		









Start September 12, 2026 12:00:06
Finish September 12, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260912120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	85.3 Hz	>100 Hz	15.1 Hz
Date	Sep 12, 2026	Sep 12, 2026	Sep 12, 2026
Time	13:30:06	15:00:06	12:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0027 in/s at September 12, 2026 13:15:06		









Start September 12, 2026 15:30:21
Finish September 13, 2026 07:29:59
Number of Intervals/Interval 63.98/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260912153021.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	0.0053 in/s	<0.005 in/s
Zero Crossing Frequency	64.0 Hz	56.9 Hz	64.0 Hz
Date	Sep 12, 2026	Sep 12, 2026	Sep 12, 2026
Time	17:45:21	17:45:21	18:15:21
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0063 in/s at September 12, 2026 17:45:21		









Start September 13, 2026 07:30:06
Finish September 13, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260913073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	64.0 Hz
Date	Sep 13, 2026	Sep 13, 2026	Sep 13, 2026
Time	10:00:06	07:45:06	09:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0042 in/s at September 13, 2026 09:45:06		









Start September 13, 2026 12:00:06
Finish September 13, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260913120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	56.9 Hz	64.0 Hz	4.1 Hz
Date	Sep 13, 2026	Sep 13, 2026	Sep 13, 2026
Time	13:45:06	14:30:06	14:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0032 in/s at September 13, 2026 14:30:06		





Start September 13, 2026 15:30:23
Finish September 14, 2026 07:29:59
Number of Intervals/Interval 63.97/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260913153023.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	0.0059 in/s
Zero Crossing Frequency	39.4 Hz	85.3 Hz	39.4 Hz
Date	Sep 14, 2026	Sep 14, 2026	Sep 14, 2026
Time	07:29:59	07:00:23	07:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	5.0	4.6	4.2
Peak Vector Sum	0.0071 in/s at September 14, 2026 07:30:23		

