

	Vibration Monitoring Report Summary		
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 08/10/2026 to 8/16/2026 Client Contact: Erik Bodker (Gilbane)
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103		
Micromate/Minimate Serial No. :	UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista		
Maximum Peak Particle Velocity (PPV) (in/sec):		Frequency (Hz) at PPV:	
UM16684	0.0462 - Vertical Channel on 08/12/2026 at 14:00:06	UM16684	85.3Hz
Maximum Specified PPV (in/sec):		0.20	
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.			
Reported By: RPC, P.E.		Reviewed By: MGD, P.E.	







Start August 10, 2026 07:30:06
Finish August 10, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260810073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0081 in/s	0.0071 in/s	0.0112 in/s
Zero Crossing Frequency	85.3 Hz	73.1 Hz	64.0 Hz
Date	Aug 10, 2026	Aug 10, 2026	Aug 10, 2026
Time	11:59:59	09:15:06	11:59:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0125 in/s at August 10, 2026 12:00:06		









Start August 10, 2026 12:00:06
Finish August 10, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260810120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0127 in/s	0.0109 in/s	0.0149 in/s
Zero Crossing Frequency	73.1 Hz	73.1 Hz	85.3 Hz
Date	Aug 10, 2026	Aug 10, 2026	Aug 10, 2026
Time	12:15:06	12:15:06	12:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0182 in/s at August 10, 2026 12:15:06		







Start August 10, 2026 15:30:20
Finish August 11, 2026 07:29:59
Number of Intervals/Interval 63.98/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260810153020.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	39.4 Hz	73.1 Hz	39.4 Hz
Date	Aug 11, 2026	Aug 11, 2026	Aug 10, 2026
Time	07:15:20	07:15:20	15:45:20
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0039 in/s at August 11, 2026 07:15:20		









Start August 11, 2026 07:30:06
Finish August 11, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260811073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0118 in/s	0.0102 in/s	0.0056 in/s
Zero Crossing Frequency	>100 Hz	85.3 Hz	64.0 Hz
Date	Aug 11, 2026	Aug 11, 2026	Aug 11, 2026
Time	11:30:06	11:30:06	11:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0147 in/s at August 11, 2026 11:30:06		









Start August 11, 2026 12:00:06
Finish August 11, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260811120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0090 in/s	0.0071 in/s	0.0099 in/s
Zero Crossing Frequency	>100 Hz	73.1 Hz	>100 Hz
Date	Aug 11, 2026	Aug 11, 2026	Aug 11, 2026
Time	15:29:59	14:00:06	15:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0116 in/s at August 11, 2026 15:00:06		







Start August 11, 2026 15:30:21
Finish August 12, 2026 07:29:59
Number of Intervals/Interval 63.98/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260811153021.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0056 in/s	<0.005 in/s	0.0068 in/s
Zero Crossing Frequency	>100 Hz	10.2 Hz	>100 Hz
Date	Aug 11, 2026	Aug 12, 2026	Aug 11, 2026
Time	15:45:21	07:29:59	15:45:21
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0078 in/s at August 11, 2026 15:45:21		









Start August 12, 2026 07:30:06
Finish August 12, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260812073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0109 in/s	0.0112 in/s	0.0096 in/s
Zero Crossing Frequency	39.4 Hz	56.9 Hz	51.2 Hz
Date	Aug 12, 2026	Aug 12, 2026	Aug 12, 2026
Time	11:59:59	11:59:59	11:59:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0139 in/s at August 12, 2026 12:00:06		









Start August 12, 2026 12:00:06
Finish August 12, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260812120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0456 in/s	0.0462 in/s	0.0332 in/s
Zero Crossing Frequency	85.3 Hz	85.3 Hz	56.9 Hz
Date	Aug 12, 2026	Aug 12, 2026	Aug 12, 2026
Time	14:00:06	14:00:06	14:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0627 in/s at August 12, 2026 14:00:06		









Start August 12, 2026 15:32:05
Finish August 13, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260812153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0084 in/s	0.0059 in/s	0.0065 in/s
Zero Crossing Frequency	42.7 Hz	25.6 Hz	39.4 Hz
Date	Aug 13, 2026	Aug 13, 2026	Aug 13, 2026
Time	07:29:59	07:17:05	07:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0086 in/s at August 13, 2026 07:32:05		






Start August 13, 2026 07:30:06
Finish August 13, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260813073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0223 in/s	0.0195 in/s	0.0158 in/s
Zero Crossing Frequency	46.5 Hz	21.3 Hz	64.0 Hz
Date	Aug 13, 2026	Aug 13, 2026	Aug 13, 2026
Time	08:15:06	08:15:06	08:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0261 in/s at August 13, 2026 08:15:06		









Start August 13, 2026 12:00:06
Finish August 13, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260813120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0168 in/s	0.0186 in/s	0.0245 in/s
Zero Crossing Frequency	39.4 Hz	28.4 Hz	34.1 Hz
Date	Aug 13, 2026	Aug 13, 2026	Aug 13, 2026
Time	12:30:06	12:30:06	12:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0261 in/s at August 13, 2026 12:30:06		












Start August 13, 2026 15:32:05
Finish August 14, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260813153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	30.1 Hz	64.0 Hz	13.1 Hz
Date	Aug 14, 2026	Aug 13, 2026	Aug 14, 2026
Time	07:29:59	16:47:05	07:29:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0037 in/s at August 14, 2026 07:32:05		









Start August 14, 2026 07:30:06
Finish August 14, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260814073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0264 in/s	0.0298 in/s	0.0214 in/s
Zero Crossing Frequency	32.0 Hz	17.7 Hz	23.3 Hz
Date	Aug 14, 2026	Aug 14, 2026	Aug 14, 2026
Time	09:00:06	09:00:06	09:00:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0326 in/s at August 14, 2026 09:00:06		







Start August 14, 2026 12:00:06
Finish August 14, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260814120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0217 in/s	0.0146 in/s	0.0062 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	42.7 Hz
Date	Aug 14, 2026	Aug 14, 2026	Aug 14, 2026
Time	14:00:06	14:00:06	12:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0224 in/s at August 14, 2026 14:00:06		






Start August 14, 2026 15:32:05
Finish August 15, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260814153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	73.1 Hz	>100 Hz	3.6 Hz
Date	Aug 14, 2026	Aug 14, 2026	Aug 15, 2026
Time	16:32:05	19:17:05	03:47:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0047 in/s at August 15, 2026 03:47:05		









Start August 15, 2026 07:30:06
Finish August 15, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260815073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	7.8 Hz
Date	Aug 15, 2026	Aug 15, 2026	Aug 15, 2026
Time	07:45:06	08:15:06	07:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0033 in/s at August 15, 2026 07:45:06		









Start August 15, 2026 12:00:06
Finish August 15, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260815120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	73.1 Hz	>100 Hz	>100 Hz
Date	Aug 15, 2026	Aug 15, 2026	Aug 15, 2026
Time	13:30:06	12:45:06	12:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0033 in/s at August 15, 2026 12:30:06		












Start August 15, 2026 15:32:05
Finish August 16, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260815153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	8.0 Hz
Date	Aug 15, 2026	Aug 16, 2026	Aug 15, 2026
Time	15:47:05	00:17:05	17:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0033 in/s at August 15, 2026 20:17:05		









Start August 16, 2026 07:30:06
Finish August 16, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260816073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0124 in/s	0.0087 in/s	0.0137 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Aug 16, 2026	Aug 16, 2026	Aug 16, 2026
Time	11:00:06	11:15:06	11:00:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0152 in/s at August 16, 2026 11:00:06		









Start August 16, 2026 12:00:06
Finish August 16, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260816120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	<1 Hz
Date	Aug 16, 2026	Aug 16, 2026	Aug 16, 2026
Time	12:30:06	15:00:06	13:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0036 in/s at August 16, 2026 13:45:06		





Start August 16, 2026 15:32:05
Finish August 17, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260816153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	51.2 Hz	16.0 Hz	42.7 Hz
Date	Aug 17, 2026	Aug 17, 2026	Aug 16, 2026
Time	07:29:59	07:29:59	19:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0039 in/s at August 17, 2026 07:32:05		

