

	Vibration Monitoring Report Summary		
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 08/17/2026 to 8/23/2026 Client Contact: Erik Bodker (Gilbane)
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103		
Micromate/Minimate Serial No. :	UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista		
Maximum Peak Particle Velocity (PPV) (in/sec):		Frequency (Hz) at PPV:	
UM16684	0.0447 - Transverse Channel on 08/18/2026 at 14:15:06	UM16684	>100 Hz
Maximum Specified PPV (in/sec):		0.20	
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.			
Reported By: RPC, P.E.		Reviewed By: MGD, P.E.	

