

	Vibration Monitoring Report Summary		
	Slauson Middle School Rennovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 08/31/2026 to 9/06/2026 Client Contact: Erik Bodker (Gilbane)
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103		
Micromate/Minimate Serial No. :	UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista		
Maximum Peak Particle Velocity (PPV) (in/sec):		Frequency (Hz) at PPV:	
UM16684	0.1195 - Transverse Channel on 09/1/2026 at 8:15:06	UM16684	23.3 Hz
Maximum Specified PPV (in/sec):		0.20	
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. No vibration threshold events occurred.			
Reported By: RPC, P.E.		Reviewed By: MGD, P.E.	







Start August 31, 2026 07:30:06
Finish August 31, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260831073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0261 in/s	0.0251 in/s	0.0239 in/s
Zero Crossing Frequency	36.6 Hz	56.9 Hz	39.4 Hz
Date	Aug 31, 2026	Aug 31, 2026	Aug 31, 2026
Time	08:45:06	08:45:06	08:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0383 in/s at August 31, 2026 08:45:06		









Start August 31, 2026 12:00:06
Finish August 31, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260831120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0285 in/s	0.0164 in/s	0.0223 in/s
Zero Crossing Frequency	>100 Hz	85.3 Hz	>100 Hz
Date	Aug 31, 2026	Aug 31, 2026	Aug 31, 2026
Time	14:45:06	14:45:06	14:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0289 in/s at August 31, 2026 14:45:06		






Start August 31, 2026 15:32:05
Finish September 1, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator


Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260831153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0127 in/s	0.0090 in/s	0.0112 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Aug 31, 2026	Aug 31, 2026	Aug 31, 2026
Time	16:47:05	17:32:05	18:32:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0162 in/s at August 31, 2026 16:47:05		





September 1, 2026 07:30:06
September 1, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260901073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes





1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	Vert	Long
0.1195 in/s	0.0801 in/s	0.0965 in/s
23.3 Hz	85.3 Hz	25.6 Hz
Sep 1, 2026	Sep 1, 2026	Sep 1, 2026
08:15:06	08:45:06	08:15:06
✔ Passed	✔ Passed	✔ Passed
7.1 Hz	7.3 Hz	7.3 Hz
4.8	4.5	4.2

Peak Vector Sum 0.1547 in/s at September 1, 2026 08:15:06





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 1, 2026 12:00:06
September 1, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260901120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0074 in/s	0.0090 in/s	0.0102 in/s
Zero Crossing Frequency	39.4 Hz	9.8 Hz	30.1 Hz
Date	Sep 1, 2026	Sep 1, 2026	Sep 1, 2026
Time	12:45:06	15:00:06	13:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0113 in/s at September 1, 2026 15:00:06		






Start September 1, 2026 15:32:05
Finish September 2, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260901153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0078 in/s	0.0127 in/s	0.0078 in/s
Zero Crossing Frequency	34.1 Hz	10.9 Hz	9.1 Hz
Date	Sep 1, 2026	Sep 1, 2026	Sep 1, 2026
Time	15:47:05	16:17:05	16:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0156 in/s at September 1, 2026 16:17:05		









Start September 2, 2026 07:30:06
Finish September 2, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260902073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0084 in/s	0.0109 in/s	0.0081 in/s
Zero Crossing Frequency	46.5 Hz	10.4 Hz	7.9 Hz
Date	Sep 2, 2026	Sep 2, 2026	Sep 2, 2026
Time	11:00:06	08:00:06	07:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0117 in/s at September 2, 2026 08:00:06		









Start September 2, 2026 12:00:06
Finish September 2, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260902120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0087 in/s	0.0155 in/s	0.0093 in/s
Zero Crossing Frequency	22.3 Hz	11.6 Hz	10.4 Hz
Date	Sep 2, 2026	Sep 2, 2026	Sep 2, 2026
Time	12:30:06	15:00:06	15:00:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.4	4.1
Peak Vector Sum	0.0182 in/s at September 2, 2026 15:00:06		







Start September 2, 2026 15:30:36
Finish September 3, 2026 07:29:59
Number of Intervals/Interval 63.96/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260902153036.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	56.9 Hz	16.5 Hz	26.9 Hz
Date	Sep 3, 2026	Sep 3, 2026	Sep 3, 2026
Time	06:45:36	06:45:36	07:00:36
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0053 in/s at September 3, 2026 06:45:36		









Start September 3, 2026 07:30:06
Finish September 3, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260903073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0155 in/s	0.0227 in/s	0.0115 in/s
Zero Crossing Frequency	>100 Hz	73.1 Hz	>100 Hz
Date	Sep 3, 2026	Sep 3, 2026	Sep 3, 2026
Time	07:45:06	07:45:06	07:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0246 in/s at September 3, 2026 07:45:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 3, 2026 12:00:06
September 3, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260903120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0065 in/s	0.0071 in/s	0.0062 in/s
Zero Crossing Frequency	46.5 Hz	64.0 Hz	39.4 Hz
Date	Sep 3, 2026	Sep 3, 2026	Sep 3, 2026
Time	14:00:06	14:00:06	12:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.4	4.1
Peak Vector Sum	0.0080 in/s at September 3, 2026 12:15:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 3, 2026 15:32:05
September 4, 2026 07:29:59
63.86/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260903153205.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0149 in/s	0.0127 in/s	0.0180 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 3, 2026	Sep 3, 2026	Sep 3, 2026
Time	16:02:05	15:47:05	15:47:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0210 in/s at September 3, 2026 16:02:05		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 4, 2026 07:30:06
September 4, 2026 11:59:59
17.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260904073006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0152 in/s	0.0177 in/s	0.0174 in/s
Zero Crossing Frequency	42.7 Hz	46.5 Hz	>100 Hz
Date	Sep 4, 2026	Sep 4, 2026	Sep 4, 2026
Time	11:00:06	11:30:06	10:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0218 in/s at September 4, 2026 11:00:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 4, 2026 12:00:06
September 4, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260904120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0093 in/s	0.0133 in/s	0.0087 in/s
Zero Crossing Frequency	51.2 Hz	51.2 Hz	>100 Hz
Date	Sep 4, 2026	Sep 4, 2026	Sep 4, 2026
Time	13:15:06	13:15:06	12:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0147 in/s at September 4, 2026 13:15:06		









Start September 4, 2026 15:32:05
Finish September 5, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260904153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0074 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	42.7 Hz	56.9 Hz	39.4 Hz
Date	Sep 4, 2026	Sep 4, 2026	Sep 4, 2026
Time	17:02:05	15:47:05	17:02:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0074 in/s at September 4, 2026 17:02:05		









Start September 5, 2026 07:30:06
Finish September 5, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260905073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0093 in/s	0.0071 in/s	0.0099 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 5, 2026	Sep 5, 2026	Sep 5, 2026
Time	10:15:06	10:15:06	10:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0126 in/s at September 5, 2026 10:15:06		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 5, 2026 12:00:06
September 5, 2026 15:29:59
13.99/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support





UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260905120006.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	42.7 Hz	73.1 Hz	56.9 Hz
Date	Sep 5, 2026	Sep 5, 2026	Sep 5, 2026
Time	13:30:06	14:30:06	13:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0031 in/s at September 5, 2026 13:00:06		









Start September 5, 2026 15:32:05
Finish September 6, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260905153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	51.2 Hz	11.1 Hz
Date	Sep 5, 2026	Sep 5, 2026	Sep 6, 2026
Time	17:17:05	16:32:05	02:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0035 in/s at September 6, 2026 02:17:05		









Start September 6, 2026 07:30:06
Finish September 6, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260906073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	51.2 Hz	51.2 Hz
Date	Sep 6, 2026	Sep 6, 2026	Sep 6, 2026
Time	11:30:06	11:59:59	11:59:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0050 in/s at September 6, 2026 11:30:06		









Start September 6, 2026 12:00:06
Finish September 6, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260906120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	30.1 Hz	>100 Hz	36.6 Hz
Date	Sep 6, 2026	Sep 6, 2026	Sep 6, 2026
Time	12:15:06	14:15:06	14:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.1
Peak Vector Sum	0.0034 in/s at September 6, 2026 14:45:06		





Start September 6, 2026 15:32:05
Finish September 7, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260906153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	<1 Hz
Date	Sep 6, 2026	Sep 6, 2026	Sep 7, 2026
Time	19:32:05	15:47:05	01:17:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.6	4.2
Peak Vector Sum	0.0041 in/s at September 7, 2026 01:17:05		

