

	<h2 style="margin: 0;">Vibration Monitoring Report Summary</h2>			
	Slauson Middle School Renovation and Addition	Project Number: 253121 Client: Ann Arbor Public Schools	Date: 09/21/26 to 09/27/26 Client Contact: Erik Bodker (Gilbane)	
	Project Address: 1019 W Washington St, Ann Arbor, MI 48103			
Micromate/Minimate Serial No. :		UM16684	Geophone Serial No.:	UM16684
Vibration Unit Location:	UM16684 - West side of school, next to property line behind 227 Buena Vista, until 9/22. Then moved to behind 231 Buena Vista.			
Maximum Peak Particle Velocity (PPV) (in/sec):			Frequency (Hz) at PPV:	
UM16684	0.1077 in/sec – Longitudinal channel on 09/23/2026 at 14:15:06		UM16684	>100 Hz
Maximum Specified PPV (in/sec): 0.20				
Description of Construction Activities: General construction activities with the intent to establish a baseline vibration level during construction. Zero (0) vibration events occurred which exceeded the maximum specified peak particle velocity (PPV). On September 22, monitoring was briefly interrupted between approximately 2:06 PM and 2:53 PM while G2 serviced the unit and relocated it to a different location on the site.				
Reported By: RPC, P.E.			Reviewed By: MGD, P.E.	







Start September 21, 2026 07:30:06
Finish September 21, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260921073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0109 in/s	0.0099 in/s	0.0102 in/s
Zero Crossing Frequency	51.2 Hz	56.9 Hz	30.1 Hz
Date	Sep 21, 2026	Sep 21, 2026	Sep 21, 2026
Time	08:30:06	08:30:06	08:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.6	4.2
Peak Vector Sum	0.0140 in/s at September 21, 2026 08:30:06		









Start September 21, 2026 12:00:06
Finish September 21, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260921120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	0.0059 in/s
Zero Crossing Frequency	46.5 Hz	21.3 Hz	36.6 Hz
Date	Sep 21, 2026	Sep 21, 2026	Sep 21, 2026
Time	14:30:06	12:45:06	15:00:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.9	4.5	4.2
Peak Vector Sum	0.0069 in/s at September 21, 2026 15:00:06		






Start September 21, 2026 15:32:05
Finish September 22, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260921153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0071 in/s	0.0062 in/s	<0.005 in/s
Zero Crossing Frequency	46.5 Hz	56.9 Hz	42.7 Hz
Date	Sep 21, 2026	Sep 21, 2026	Sep 21, 2026
Time	22:02:05	22:02:05	18:02:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	5.0	4.6	4.3
Peak Vector Sum	0.0084 in/s at September 21, 2026 22:02:05		









Start September 22, 2026 07:30:06
Finish September 22, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.7 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260922073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0102 in/s	0.0074 in/s	0.0087 in/s
Zero Crossing Frequency	46.5 Hz	64.0 Hz	42.7 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	09:30:06	11:15:06	09:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	5.0	4.6	4.3
Peak Vector Sum	0.0119 in/s at September 22, 2026 11:15:06		









Start September 22, 2026 12:00:06
Finish September 22, 2026 14:06:45
Number of Intervals/Interval 8.44/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260922120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0245 in/s	0.0084 in/s	0.0180 in/s
Zero Crossing Frequency	36.6 Hz	>100 Hz	42.7 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	14:06:45	14:06:45	14:06:45
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.1 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.5	4.2
Peak Vector Sum	0.0276 in/s at September 22, 2026 14:15:06		







Start September 22, 2026 14:19:22
Finish September 22, 2026 14:19:35
Number of Intervals/Interval 0.01/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260922141922.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	46.5 Hz	>100 Hz	>100 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	14:19:35	14:19:35	14:19:35
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.5	4.1
Peak Vector Sum	0.0033 in/s at September 22, 2026 14:34:22		





Start
Finish
Number of Intervals/Interval
Sample Rate
Setup File Name
Operator

September 22, 2026 14:19:42
September 22, 2026 14:33:32
0.92/900 sec
1024 sps
253121 Slauson Middle School.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support




UM16684
Micromate ISEE 11.0BD
3.8 volts
July 26, 2025 by Instantel
UM16684_20260922141942.IDFH
Disabled

Notes
Location
Client
Company
General Notes

1019 W Washington St, Ann Arbor, MI
Gilbane Building Company
G2 Consulting Group, LLC
G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0112 in/s	0.0096 in/s	0.0084 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	14:33:32	14:33:32	14:33:32
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.5	4.1
Peak Vector Sum	0.0137 in/s at September 22, 2026 14:34:42		







Start September 22, 2026 14:34:35
Finish September 22, 2026 14:40:46
Number of Intervals/Interval 0.41/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260922143435.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	>100 Hz	56.9 Hz	32.0 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	14:40:46	14:40:46	14:40:46
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.5	4.1
Peak Vector Sum	0.0032 in/s at September 22, 2026 14:49:35		









Start September 22, 2026 14:53:28
Finish September 22, 2026 15:29:59
Number of Intervals/Interval 2.43/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260922145328.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0292 in/s	0.0130 in/s	0.0189 in/s
Zero Crossing Frequency	85.3 Hz	85.3 Hz	73.1 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	15:08:28	15:08:28	15:08:28
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.5	4.1
Peak Vector Sum	0.0315 in/s at September 22, 2026 15:08:28		









Start September 22, 2026 15:32:05
Finish September 23, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260922153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0149 in/s	0.0065 in/s	0.0146 in/s
Zero Crossing Frequency	>100 Hz	12.2 Hz	16.0 Hz
Date	Sep 22, 2026	Sep 22, 2026	Sep 22, 2026
Time	15:47:05	17:47:05	17:47:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0171 in/s at September 22, 2026 15:47:05		









Start September 23, 2026 07:30:06
Finish September 23, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260923073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0658 in/s	0.0413 in/s	0.0444 in/s
Zero Crossing Frequency	36.6 Hz	73.1 Hz	85.3 Hz
Date	Sep 23, 2026	Sep 23, 2026	Sep 23, 2026
Time	11:59:59	11:59:59	11:59:59
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0659 in/s at September 23, 2026 12:00:06		








Start September 23, 2026 12:00:06
Finish September 23, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260923120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0506 in/s	0.0524 in/s	0.1077 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 23, 2026	Sep 23, 2026	Sep 23, 2026
Time	14:15:06	14:15:06	14:15:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.6	4.1
Peak Vector Sum	0.1221 in/s at September 23, 2026 14:15:06		









Start September 23, 2026 15:31:07
Finish September 24, 2026 07:29:59
Number of Intervals/Interval 63.92/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260923153107.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0087 in/s	0.0078 in/s	0.0096 in/s
Zero Crossing Frequency	5.8 Hz	39.4 Hz	42.7 Hz
Date	Sep 24, 2026	Sep 23, 2026	Sep 23, 2026
Time	02:01:07	17:46:07	17:46:07
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0128 in/s at September 23, 2026 17:46:07		









Start September 24, 2026 07:30:06
Finish September 24, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260924073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0236 in/s	0.0192 in/s	0.0180 in/s
Zero Crossing Frequency	15.5 Hz	21.3 Hz	19.7 Hz
Date	Sep 24, 2026	Sep 24, 2026	Sep 24, 2026
Time	09:30:06	09:30:06	09:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0329 in/s at September 24, 2026 09:30:06		









Start September 24, 2026 12:00:06
Finish September 24, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260924120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0295 in/s	0.0385 in/s	0.0310 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 24, 2026	Sep 24, 2026	Sep 24, 2026
Time	12:45:06	12:45:06	12:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.6	4.1
Peak Vector Sum	0.0495 in/s at September 24, 2026 12:45:06		









Start September 24, 2026 15:32:05
Finish September 25, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260924153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0106 in/s	0.0062 in/s	0.0096 in/s
Zero Crossing Frequency	20.5 Hz	20.5 Hz	23.3 Hz
Date	Sep 24, 2026	Sep 24, 2026	Sep 24, 2026
Time	17:02:05	17:02:05	17:02:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0146 in/s at September 24, 2026 17:02:05		









Start September 25, 2026 07:30:06
Finish September 25, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260925073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0099 in/s	0.0084 in/s	0.0071 in/s
Zero Crossing Frequency	12.5 Hz	13.1 Hz	28.4 Hz
Date	Sep 25, 2026	Sep 25, 2026	Sep 25, 2026
Time	07:45:06	07:45:06	07:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0118 in/s at September 25, 2026 07:45:06		









Start September 25, 2026 12:00:06
Finish September 25, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260925120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0214 in/s	0.0137 in/s	0.0195 in/s
Zero Crossing Frequency	28.4 Hz	73.1 Hz	24.4 Hz
Date	Sep 25, 2026	Sep 25, 2026	Sep 25, 2026
Time	13:45:06	13:45:06	13:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.6	4.2
Peak Vector Sum	0.0231 in/s at September 25, 2026 13:45:06		












Start September 25, 2026 15:32:05
Finish September 26, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260925153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0143 in/s	0.0155 in/s	0.0109 in/s
Zero Crossing Frequency	8.5 Hz	>100 Hz	34.1 Hz
Date	Sep 25, 2026	Sep 25, 2026	Sep 25, 2026
Time	18:47:05	19:32:05	18:47:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0179 in/s at September 25, 2026 18:47:05		









Start September 26, 2026 07:30:06
Finish September 26, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260926073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0168 in/s	0.0189 in/s	0.0217 in/s
Zero Crossing Frequency	>100 Hz	>100 Hz	>100 Hz
Date	Sep 26, 2026	Sep 26, 2026	Sep 26, 2026
Time	08:45:06	08:00:06	08:00:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0254 in/s at September 26, 2026 08:00:06		









Start September 26, 2026 12:00:06
Finish September 26, 2026 15:29:59
Number of Intervals/Interval 13.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260926120006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0230 in/s	0.0155 in/s	0.0310 in/s
Zero Crossing Frequency	>100 Hz	73.1 Hz	>100 Hz
Date	Sep 26, 2026	Sep 26, 2026	Sep 26, 2026
Time	12:30:06	12:30:06	12:30:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.7	4.6	4.1
Peak Vector Sum	0.0411 in/s at September 26, 2026 12:30:06		









Start September 26, 2026 15:32:05
Finish September 27, 2026 07:29:59
Number of Intervals/Interval 63.86/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260926153205.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0158 in/s	0.0090 in/s	0.0084 in/s
Zero Crossing Frequency	17.1 Hz	18.3 Hz	16.5 Hz
Date	Sep 26, 2026	Sep 26, 2026	Sep 26, 2026
Time	19:02:05	19:02:05	19:02:05
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0183 in/s at September 26, 2026 19:02:05		





Start September 27, 2026 07:30:06
Finish September 27, 2026 11:59:59
Number of Intervals/Interval 17.99/900 sec
Sample Rate 1024 sps
Setup File Name 253121 Slauson Middle School.mmb
Operator Operator

Serial Number UM16684
Model Number Micromate ISEE 11.0BD
Battery Level 3.8 volts
Unit Calibration July 26, 2025 by Instantel
Event File Name UM16684_20260927073006.IDFH
USB Sensor Support Disabled

Notes
Location 1019 W Washington St, Ann Arbor, MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 No. 253121

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	0.0127 in/s	0.0121 in/s	0.0130 in/s
Zero Crossing Frequency	23.3 Hz	32.0 Hz	26.9 Hz
Date	Sep 27, 2026	Sep 27, 2026	Sep 27, 2026
Time	10:30:06	08:45:06	08:45:06
Sensor Check	✓ Passed	✓ Passed	✓ Passed
Frequency	7.3 Hz	7.3 Hz	7.3 Hz
Overswing Ratio	4.8	4.6	4.2
Peak Vector Sum	0.0168 in/s at September 27, 2026 08:45:06		

