

	Vibration Monitoring Report Summary			
	Thurston Elementary School	Project Number: 233473		Date: 09/21/26 to 09/27/26
	Client: Ann Arbor Public Schools		Client Contact: Erik Bodker (Gilbane)	
Project Address: 2300 Prairie Street, Ann Arbor MI				
Micromate/Minimate Serial No. :		UM17584	Geophone Serial No.:	UM17584
Vibration Unit Location:	UM17584 - Northeast side of site approximately 100 feet west of edge of house at 2219 Georgetown Boulevard			
Maximum Peak Particle Velocity (PPV) (in/sec):			Frequency (Hz) at PPV:	
UM17584	0.020 in/sec - Longitudinal channel on 09/25/2026 at 14:17:06		UM17584	73 Hz
Maximum Specified PPV (in/sec):		0.20		
Description of Construction Activities: G2 understands that construction activities consist of utility installation with backfilling operations taking place using an excavator with a hoe-pack attachment. No vibration events exceeding the maximum specified threshold occurred.				
Reported By: RPC, P.E.			Reviewed By: JBS, P.E.	

Histogram Start Time 12:02:06 September 21, 2026
Histogram Finish Time 16:59:59 September 21, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260921120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.009	0.007	0.008	in/s
ZC Freq	27	13	32	Hz
Date	Sep 21 /26	Sep 21 /26	Sep 21 /26	
Time	13:02:06	12:17:06	12:47:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.7	

Peak Vector Sum 0.009 in/s on September 21, 2026 at 13:02:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 21, 2026
Histogram Finish Time 07:29:59 September 22, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260921170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.007	0.006	0.007	in/s
ZC Freq	22	14	21	Hz
Date	Sep 22 /26	Sep 22 /26	Sep 22 /26	
Time	07:17:06	06:17:06	07:02:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.2	4.4	4.7	

Peak Vector Sum 0.008 in/s on September 22, 2026 at 07:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:06 September 22, 2026
Histogram Finish Time 11:59:59 September 22, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260922073206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.015	0.007	0.009	in/s
ZC Freq	34	18	17	Hz
Date	Sep 22 /26	Sep 22 /26	Sep 22 /26	
Time	11:47:06	10:02:06	11:32:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.8	

Peak Vector Sum 0.017 in/s on September 22, 2026 at 11:47:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:06 September 22, 2026
Histogram Finish Time 16:59:59 September 22, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260922120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.012	0.009	0.015	in/s
ZC Freq	51	14	64	Hz
Date	Sep 22 /26	Sep 22 /26	Sep 22 /26	
Time	14:17:06	15:02:06	14:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.7	

Peak Vector Sum 0.017 in/s on September 22, 2026 at 14:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 22, 2026
Histogram Finish Time 07:29:59 September 23, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260922170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.013	0.014	0.010	in/s
ZC Freq	16	16	13	Hz
Date	Sep 23 /26	Sep 23 /26	Sep 23 /26	
Time	07:02:06	07:02:06	06:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.2	4.4	4.7	

Peak Vector Sum 0.014 in/s on September 23, 2026 at 06:47:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:06 September 23, 2026
Histogram Finish Time 09:42:04 September 23, 2026
Number of Intervals 8.66 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260923073206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.012	0.007	0.006	in/s
ZC Freq	73	12	26	Hz
Date	Sep 23 /26	Sep 23 /26	Sep 23 /26	
Time	09:42:04	08:02:06	08:02:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.7	

Peak Vector Sum 0.012 in/s on September 23, 2026 at 09:42:04



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 09:45:59 September 23, 2026
Histogram Finish Time 11:59:59 September 23, 2026
Number of Intervals 8.93 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260923094559.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.011	0.008	0.013	in/s
ZC Freq	34	27	64	Hz
Date	Sep 23 /26	Sep 23 /26	Sep 23 /26	
Time	10:45:59	10:45:59	10:00:59	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.7	

Peak Vector Sum 0.014 in/s on September 23, 2026 at 10:45:59



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:06 September 23, 2026
Histogram Finish Time 16:59:59 September 23, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260923120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.011	0.010	0.009	in/s
ZC Freq	32	>100	30	Hz
Date	Sep 23 /26	Sep 23 /26	Sep 23 /26	
Time	13:32:06	12:47:06	13:32:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.7	

Peak Vector Sum 0.012 in/s on September 23, 2026 at 12:47:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 23, 2026
Histogram Finish Time 07:29:59 September 24, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by InstanTEL
File Name UM17584_20260923170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.011	0.010	0.014	in/s
ZC Freq	15	16	18	Hz
Date	Sep 24 /26	Sep 24 /26	Sep 24 /26	
Time	06:32:06	06:32:06	06:32:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.2	4.4	4.7	

Peak Vector Sum 0.015 in/s on September 24, 2026 at 06:32:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:06 September 24, 2026
Histogram Finish Time 11:59:59 September 24, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260924073206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.010	0.013	0.007	in/s
ZC Freq	16	14	24	Hz
Date	Sep 24 /26	Sep 24 /26	Sep 24 /26	
Time	08:17:06	08:17:06	10:47:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.8	

Peak Vector Sum 0.014 in/s on September 24, 2026 at 08:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:06 September 24, 2026
Histogram Finish Time 16:59:59 September 24, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260924120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.012	0.008	0.010	in/s
ZC Freq	23	13	30	Hz
Date	Sep 24 /26	Sep 24 /26	Sep 24 /26	
Time	12:17:06	14:47:06	15:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.8	

Peak Vector Sum 0.012 in/s on September 24, 2026 at 12:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 24, 2026
Histogram Finish Time 07:29:59 September 25, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260924170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.008	0.005	0.005	in/s
ZC Freq	51	12	64	Hz
Date	Sep 24 /26	Sep 25 /26	Sep 24 /26	
Time	18:47:06	07:02:06	18:47:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.1	4.2	4.5	

Peak Vector Sum 0.009 in/s on September 24, 2026 at 18:47:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:06 September 25, 2026
Histogram Finish Time 11:59:59 September 25, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260925073206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.007	0.007	0.007	in/s
ZC Freq	32	>100	85	Hz
Date	Sep 25 /26	Sep 25 /26	Sep 25 /26	
Time	10:32:06	10:17:06	10:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.7	

Peak Vector Sum 0.008 in/s on September 25, 2026 at 10:32:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:06 September 25, 2026
Histogram Finish Time 16:59:59 September 25, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260925120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.015	0.007	0.020	in/s
ZC Freq	57	14	73	Hz
Date	Sep 25 /26	Sep 25 /26	Sep 25 /26	
Time	14:17:06	14:02:06	14:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.7	

Peak Vector Sum 0.023 in/s on September 25, 2026 at 14:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 25, 2026
Histogram Finish Time 07:29:59 September 26, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260925170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.008	0.004	0.012	in/s
ZC Freq	51	51	64	Hz
Date	Sep 25 /26	Sep 25 /26	Sep 25 /26	
Time	18:47:06	19:02:06	18:32:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.2	4.3	4.6	

Peak Vector Sum 0.012 in/s on September 25, 2026 at 18:32:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:06 September 26, 2026
Histogram Finish Time 11:59:59 September 26, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260926073206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.005	0.002	0.004	in/s
ZC Freq	57	>100	43	Hz
Date	Sep 26 /26	Sep 26 /26	Sep 26 /26	
Time	08:17:06	10:02:06	08:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.8	

Peak Vector Sum 0.005 in/s on September 26, 2026 at 08:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:06 September 26, 2026
Histogram Finish Time 16:59:59 September 26, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260926120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
Client Gilbane Building Company
Company G2 Consulting Group, LLC
General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.003	0.002	0.003	in/s
ZC Freq	47	85	85	Hz
Date	Sep 26 /26	Sep 26 /26	Sep 26 /26	
Time	13:32:06	15:17:06	15:47:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.7	

Peak Vector Sum 0.004 in/s on September 26, 2026 at 13:32:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 26, 2026
Histogram Finish Time 07:29:59 September 27, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260926170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.003	0.002	0.002	in/s
ZC Freq	64	>100	>100	Hz
Date	Sep 26 /26	Sep 26 /26	Sep 26 /26	
Time	17:17:06	21:17:06	17:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.1	4.2	4.5	

Peak Vector Sum 0.003 in/s on September 26, 2026 at 17:17:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 07:32:06 September 27, 2026
Histogram Finish Time 11:59:59 September 27, 2026
Number of Intervals 17.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260927073206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.002	0.002	0.002	in/s
ZC Freq	>100	85	>100	Hz
Date	Sep 27 /26	Sep 27 /26	Sep 27 /26	
Time	10:47:06	11:59:59	07:47:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.5	4.8	

Peak Vector Sum 0.003 in/s on September 27, 2026 at 07:47:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 12:02:06 September 27, 2026
Histogram Finish Time 16:59:59 September 27, 2026
Number of Intervals 19.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260927120206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.002	0.002	0.002	in/s
ZC Freq	30	22	N/A	Hz
Date	Sep 27 /26	Sep 27 /26	Sep 27 /26	
Time	12:17:06	12:17:06	12:17:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.3	4.4	4.7	

Peak Vector Sum 0.003 in/s on September 27, 2026 at 12:17:06
N/A: Not Applicable



Time Scale: 15 minutes /div Amplitude Scale: Geo: 0.050 in/s/div

Sensor Check

Histogram Start Time 17:02:06 September 27, 2026
Histogram Finish Time 07:29:59 September 28, 2026
Number of Intervals 57.86 at 15 minutes
Range Geo:10.000 in/s
Sample Rate 1024sps
Operator/Setup: Operator/233473 Thurston Elementary School.mmb

Serial Number UM17584 V 11-OCB Micromate ISEE
Battery Level 3.8 Volts
Unit Calibration January 22, 2026 by Instantel
File Name UM17584_20260927170206.IDFH


Notes

Location Thurston Elementary School, Ann Arbor MI
 Client Gilbane Building Company
 Company G2 Consulting Group, LLC
 General Notes G2 Project No. 233473

Extended Notes

	Tran	Vert	Long	
PPV	0.015	0.010	0.011	in/s
ZC Freq	64	9.8	6.8	Hz
Date	Sep 27 /26	Sep 28 /26	Sep 28 /26	
Time	18:47:06	07:17:06	07:02:06	
Sensor Check	Passed	Passed	Passed	
Frequency	7.5	7.3	7.3	Hz
Overswing Ratio	4.1	4.2	4.5	

Peak Vector Sum 0.015 in/s on September 27, 2026 at 18:47:06



Time Scale: 15 minutes /div **Amplitude Scale:** Geo: 0.050 in/s/div

Sensor Check